



- NOTES:
1. METER SOCKET MOUNTED OUTDOORS EXCEPT WHERE SPECIAL PERMISSION OBTAINED.
 2. NEWNAN UTILITIES TO MAKE ALL SERVICE LATERAL CONNECTIONS AT POLE OR PADMOUNT TRANSFORMER AND ALL METERING CONTROL CABLE CONNECTIONS IN METER SOCKET AND C.T. CABINET. CUSTOMER TO MAKE ALL CONNECTIONS IN WIRE TROUGH.
 3. CONDUCTOR CARRYING METERED AND UN-METERED ENERGY SHALL NOT BE ALLOWED IN SAME WIRING TROUGH OR CONDUIT.

TYPICAL UNDERGROUND COMMERCIAL 3 ϕ
 INSTALLATION WITH MULTIPLE CUSTOMERS
 ON COMMON SERVICE LATERAL